

County	Name of Water Supply	Scheme Code	Population Served	Volume Supplied (m3/day)	Proposed Action Programme	Proposed Date of Completion of Action Programme (This is the date by which works are complete. There will be a further 3 month period to demonstrate the effectiveness of works before the supply is removed from the RAL.)	RAL Categories									
							Inadequate Treatment for Cryptosporidium	Inadequate Treatment - Inadequate Disinfection	Failed to meet E coli/Enterococci standard in the Drinking Water Regulations	Elevated Levels of THMs above the standard in the Drinking Water Regulations	Elevated Levels of Pesticides above the standard in the Drinking Water Regulations	Supply identified by the HSE where further investigation or improvement may be required	Excessive levels of aluminium in the treated water	Poor turbidity removal	EPA Audit Observation - Treatment and Management Issues	
Cavan	Baileborough	0200PUB0102	7785	2237	To be submitted by Irish Water	To be submitted by Irish Water										Y
Cavan	Belturbet	0200PUB0108	1926	571	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction requires compliance by Dec-20					Y					
Cavan	Cavan RWSS	0200PUB0100	11448	4019	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction requires compliance by Dec-20					Y					
Cavan	Swanlinbar	0200PUB0117	301	93	Upgrade of water treatment plant	EPA Direction requires compliance by Sept 20										Y
Cavan	Shercock	0200PUB0116	712	209	To be confirmed by Irish Water	Irish Water has not confirmed a RAL completion date. This is contingent on the planned operational review of the treatment plant (which is operated under a private Group Water Scheme).							Y			
Cavan	Dowra PWS	0200PUB0111	92	46	To be confirmed by Irish Water	Irish Water has not confirmed a RAL completion date. This is contingent on the planned operational review of the treatment plant (which is operated under a private Group Water Scheme).							Y			
Clare	Corofin	0300PUB1010	1,276	330	Upgrade of water treatment plant	Jun-21										Y
Clare	Ennistymon RWS	0300PUB1004	6,961	6,254	Upgrade of water treatment plant	Sep-22										Y
Clare	West Clare RWS (New WTP)	0300PUB1066	11,370	13,175	Upgrade of water treatment plant	Sep-21				Y						
Cork	Ballingeary	0500PUB2302	239	79	Upgrade of water treatment plant	Complete but need verification of the effectiveness of the action programme				Y						
Cork	Ballyhooly	0500PUB1203	1,196	982	Upgrade of water treatment plant	Apr-20	Y									
Cork	Glashaboy	0500PUB3303	22,808	19,143	To be submitted by Irish Water	To be submitted by Irish Water										Y
Cork	Glengarriff	0500PUB4208	353	358	Upgrade of water treatment plant	Mar-21	Y			Y						
Cork	Kealkill	0500PUB4105	701	319	Upgrade of water treatment plant	Complete but need verification of the effectiveness of the action programme				Y						
Cork	Leap	0500PUB4604	497	283	Abandon source and connect to Skibbereen water treatment plant	Jan-21				Y						
Cork	Schull	0500PUB4503	946	631	Abandon source and connect to Skibbereen water treatment plant	Aug-20				Y						
Cork City	Cork City Water Supply	0400PUB1001	87,114	41,349	Upgrade of water treatment plant	Sep-21										Y
Donegal	Glenties-Ardara	0600PUB1070	3,536	1,669	To be submitted by Irish Water	To be submitted by Irish Water				Y						

Mayo	Newport PWS	2200PUB1022	684	312	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction requires compliance by Dec-21						Y					
Meath	Drumcondrath	2300PUB1005	1,182	544	Upgrade of water treatment plant	Irish Water has not confirmed a date for completion of the action programme						Y					
Meath	Navan & MidMeath PWS	2300PUB1016	38,985	11,004	Upgrade of water treatment plant	Jun-20											Y
Offaly	Clara/Ferbane RWSS	2500PUB1003	7,467	5,145	Upgrade of coagulation process at Clara water treatment plant	Irish Water has not confirmed a date for completion of the action programme						Y					
Sligo	Lough Talt Regional Water Supply	2700PUB2702	12,576	7,908	New water treatment plant to be constructed	Dec-20	Y					Y					
Tipperary	Clonmel Poulavanogue	2900PUB0109	2,566	1,756	Replace with an alternative groundwater source	Irish Water has not confirmed a date for completion of the action programme	Y										
Tipperary	Galtee Regional	2900PUB0130	11,436	8,373	Upgrade of coagulation process at water treatment plant	Jun-20								Y	Y	Y	
Wexford	Clonroche	3300PUB1452	522	253	Complete catchment-focussed engagement actions involving Irish Water and the relevant stakeholders (as set out in Irish Water's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction requires compliance by Jan-21						Y					
Wicklow	Aughrim / Annacurra	3400PUB1023	1,594	368	Abandon source of the water supply and replace with new borehole source and new treatment to be installed	Irish Water has not confirmed a date for completion of the action programme						Y					
Wicklow	Enniskerry Public Supply	3400PUB1019	2,667	853	Upgrade of Vartry Water Treatment Plant	Mar-21						Y					Y
Wicklow	Wicklow Regional Public Supply	3400PUB1005	15,598	4,479	Upgrade of Vartry Water Treatment Plant	Mar-21						Y					Y
Wicklow	Bray	3400PUB1001	28,934	7,916	Upgrade of Vartry Water Treatment Plant	Mar-21						Y					Y
Wicklow	Greystones/Windgates/Te mplecarraig	3400PUB1003	16,380	4,185	Upgrade of Vartry Water Treatment Plant	Mar-21						Y					Y
Wicklow	Kilmacanogue	3400PUB1009	1,237	331	Upgrade of Vartry Water Treatment Plant	Mar-21						Y					Y
Wicklow	Newtown Newcastle Kilcoole	3400PUB1010	12,724	3,261	Upgrade of Vartry Water Treatment Plant	Mar-21						Y					Y